

"Environmental Protection Plan (Non-Radiological)," of the licenses to remove a parenthetical reference to a superseded section of 10 CFR part 51.

*Date of issuance:* January 21, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 211 & 205.

*Facility Operating License Nos. DPR-29 and DPR-30:* The amendments revised Appendix B of the licenses.

*Date of initial notice in **Federal Register**:* October 29, 2002 (67 FR 66009).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 21, 2003.

No significant hazards consideration comments received: No.

*Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska*

*Date of amendment request:* October 8, 2002.

*Brief description of amendment:* The amendment relocates Technical Specification 2.13, "Nuclear Detector Cooling System," and its associated Bases to the Fort Calhoun Station Updated Safety Analysis Report.

*Date of issuance:* January 16, 2003.

*Effective date:* January 16, 2003, and shall be implemented within 120 days of the date of issuance. Implementation includes the incorporation of changes to the Fort Calhoun Station Updated Safety Analysis Report as described in the licensee's application dated October 8, 2002.

*Amendment No.:* 214.

*Facility Operating License No. DPR-40:* Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* November 12, 2002 (67 FR 68741).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 16, 2003.

No significant hazards consideration comments received: No.

*Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska*

*Date of amendment request:* July 22, 2002, as supplemented by letter dated October 8, 2002.

*Brief description of amendment:* The amendment revises Technical Specification (TS) 5.19, Surveillance Requirement (SR) 3.0.4 and adds TS 5.20 and SR 3.0.5 to extend the delay period before entering a limiting condition for operation following a missed surveillance.

*Date of issuance:* January 16, 2003.

*Effective date:* January 16, 2003, and shall be implemented with 120 days from the date of issuance, including the incorporation of changes to the technical specification Bases as described in the licensee's application dated July 22, 2002, as supplemented by letter dated October 8, 2002.

*Amendment No.:* 215.

*Facility Operating License No. DPR-40:* Amendment revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* September 3, 2002 (67 FR 56326).

The supplemental letter of October 8, 2002, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 16, 2003.

No significant hazards consideration comments received: No.

*PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania*

*Date of application for amendments:* September 23, 2002.

*Brief description of amendments:* These amendments revised Technical Specification (TS) section 2.6.2.4, "Residual Heat Removal [RHR] Suppression Pool Cooling," to adopt TS Task Force (TF) change 230, Revision 1 (TSTF-230, Revision 1). This change to Required Action B of Limiting Condition for Operation 3.6.2.3 allows two RHR suppression pool cooling subsystems to be inoperable for up to 8 hours.

*Date of issuance:* January 16, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 207, 181.

*Facility Operating License Nos. NPF-14 and NPF-22:* The amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* October 29, 2002 (67 FR 66012). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 16, 2003.

No significant hazards consideration comments received: No.

*PSEG Nuclear LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey*

*Date of application for amendment:* December 17, 2002, as supplemented December 31, 2002.

*Brief description of amendment:* The amendment provides a one-time change to Technical Specification (TS) 4.8.1.1.2.h.14 to allow the testing of Hope Creek's emergency diesel generator (EDG) lockout relays to be performed at power until startup from its eleventh refueling outage (spring 2003). The current TS surveillance requirement only allows the EDG lockout relays to be tested during shutdown conditions. PSEG requested that the TS change be issued on an exigent basis in accordance with title 10 of the Code of Federal Regulations (10 CFR), part 50, section 50.91(a)(6). Approval and implementation of the TS change allows the testing that has been completed to be used to comply with TS 4.8.1.1.2.h.14.

*Date of issuance:* January 10, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days.

*Amendment No.:* 141.

*Facility Operating License No. NPF-57:* This amendment revised the Technical Specifications.

*Public Comments Requested as to Proposed No Significant Hazards Consideration:* Yes (67 FR 79163) December 27, 2002. That notice provided an opportunity to submit comments on the Commission's proposed no significant hazards consideration determination. No comments have been received. The notice also provided for an opportunity to request a hearing by January 27, 2003, but indicated that if the Commission makes a final no significant hazards consideration determination, any such hearing would take place after the issuance of the amendment. The Commission's related evaluation of the amendment, finding of exigent circumstances, final determination of no significant hazards consideration, and state consultation are contained in a safety evaluation dated January 10, 2003.

*NRC Section Chief:* James W. Clifford.

*STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas*

*Date of amendments request:* February 18, 2002, as supplemented in letter dated July 23, 2002.

*Brief description of amendments:* The proposed amendments revised