

contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** Notice. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 29, 2003.

No significant hazards consideration comments received: No.

AmerGen Energy Company, LLC, Docket No. 50-289, Three Mile Island Nuclear Station, Unit 1 (TMI-1), Dauphin County, Pennsylvania

Date of application for amendment: January 14, 2003.

Brief description of amendment: The amendment revised technical specification sections 3.8.9, 3.15.2, 4.12.2, and associated Bases to delete the requirements for the reactor building purge air treatment system.

Date of issuance: September 23, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 245.

Facility Operating License No. DPR-50: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: (68 FR 10278) March 4, 2003. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 23, 2003.

No significant hazards consideration comments received: No.

AmerGen Energy Company, LLC, Docket No. 50-289, Three Mile Island Nuclear Station, Unit 1 (TMI-1), Dauphin County, Pennsylvania

Date of application for amendment: September 20, 2002.

Brief description of amendment: The amendment revises the Technical Specification (TS) definition of containment integrity to ensure that all power-operated valves, relief valves, and check valves are included and clarifies the handling of operability and reportability issues related to Type III containment isolation valves. The amendment also includes minor administrative and editorial changes to improve the consistency and clarity of the TSs.

Date of issuance: September 30, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 246.

Facility Operating License No. DPR-50: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68729). The Commission's related

evaluation of the amendment is contained in a Safety Evaluation dated September 30, 2003.

No significant hazards consideration comments received: No.

Arizona Public Service Company, et al., Docket No. STN 50-529, Palo Verde Nuclear Generating Station, Unit No. 2, Maricopa County, Arizona

Date of application for amendment: December 21, 2001, as supplemented by letters dated March 13, August 27, August 29, September 4, September 6, October 11, November 21, December 10, December 23, 2002, and March 11, June 10, July 25, and August 22, 2003.

Brief description of amendment: The amendment changes the Unit 2 Technical Specifications and operating license to support (1) replacement of the steam generators and (2) the subsequent operation at an increased maximum power level of 3990 MWt, which is a 2.94 percent increase from the current 3876 MWt.

Date of issuance: September 29, 2003.

Effective date: This license amendment is effective as of the date of issuance, and shall be implemented prior to entry into Mode 4 during the restart from the Fall 2003 refueling outage.

Amendment No.: Unit 2-149.

Facility Operating License No. NPF-51: The amendment revised the Technical Specifications and Operating License.

Date of initial notice in Federal Register: February 19, 2002 (67 FR 7412). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 29, 2003.

No significant hazards consideration comments received: No.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: August 14, 2002, as supplemented on March 11, May 16, and May 23, 2003.

Brief description of amendment: The amendment revises the Technical Specifications (TSs) related to reactivity control systems, power distribution limits, and special test exceptions.

Date of issuance: September 25, 2003.

Effective date: As of the date of issuance and shall be implemented within 90 days from the date of issuance.

Amendment No.: 280.

Facility Operating License No. DPR-65: This amendment revised the TSs.

Date of initial notice in Federal Register: September 17, 2002 (67 FR

58640). The supplements dated March 11, May 16, and May 23, 2003, provided additional information which clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 30, 2003.

No significant hazards consideration comments received: No.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: August 7, 2002, as supplemented on October 23, 2002.

Brief description of amendment: The amendment revises Technical Specification (TS) 6.9.1.8, "Core Operating Limits Report," to update the list of documents that describe the analytical methods used to determine the core operating limits.

Date of issuance: September 25, 2003.

Effective date: As of the date of issuance and shall be implemented prior to Mode 4 operation of Cycle 16.

Amendment No.: 281.

Facility Operating License No. DPR-65: This amendment revised the TSs.

Date of initial notice in Federal Register: September 17, 2002 (67 FR 58639). The supplement dated October 23, 2002, provided additional information which clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 25, 2003.

No significant hazards consideration comments received: No.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit No. 2, New London County, Connecticut

Date of application for amendment: May 7, 2002, as supplemented on January 16, May 27, July 1, and August 21, 2003.

Brief description of amendment: The amendment revises Technical Specifications (TSs) 2.2, "Limiting Safety System Settings" and 3/4.3, "Instrumentation" to more accurately reflect the existing plant design for the Reactor Protection System, the Engineered Safety Features Actuation System, and the Radiation Monitoring System instrumentation and to provide