

consistency within the associated TS Tables.

*Date of issuance:* September 25, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 90 days from the date of issuance.

*Amendment No.:* 282.

*Facility Operating License No. DPR-65:* This amendment revises the TSs.

*Date of initial notice in **Federal Register**:* June 25, 2002 (67 FR 42819). The supplements dated January 16, May 27, July 1, and August 21, 2003, provided additional information which clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 25, 2003.

*No significant hazards consideration comments received:* No.

*Dominion Nuclear Connecticut, Inc., Docket No. 50-423, Millstone Power Station, Unit No. 3, New London County, Connecticut*

*Date of application for amendment:* August 14, 2002, as supplemented December 19, 2002.

*Brief description of amendment:* The amendment revised the Technical Specifications (TSs) related to Containment Systems. Specifically, the revisions: (1) Added clarification to TS 1.7, "Definitions—Containment Integrity;" (2) added clarifying information, as well as revised a portion of Surveillance Requirement 4.6.1.1 associated with the affected section of TS 3.6.1.1, "Containment Integrity;" (3) revised TS 3.6.3, "Containment Isolation Valves," that made editorial changes, added clarifying information, and added an Action item that increased the allowed outage time from 4 hours to 72 hours for Containment Isolation Valves in closed systems; and (4) made other changes that were clarifying and/or administrative in nature. In addition, the TS Bases were revised to address these changes, as appropriate.

*Date of issuance:* September 29, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 90 days from the date of issuance.

*Amendment No.:* 216.

*Facility Operating License No. NPF-49:* This amendment revised the TSs.

*Date of initial notice in **Federal Register**:* October 1, 2002 (67 FR 61678). The December 19, 2002, letter provided clarifying information that did not change the initial proposed no significant hazards consideration

determination or expand the amendment beyond the scope of the initial notice. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 29, 2003.

*No significant hazards consideration comments received:* No.

*Duke Energy Corporation, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear Station, Units 1 and 2, York County, South Carolina*

*Date of application for amendments:* December 20, 2001, as supplemented by letters dated March 4, 2002, September 12, 2002, November 20, 2002, and August 28, 2003.

*Brief description of amendments:* The amendments revised the Technical Specifications (TS) 3.3.2, Engineered Safety Features Actuation System Instrumentation.

*Date of issuance:* September 10, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days from the date of issuance.

*Amendment Nos.:* 208 and 202.

*Facility Operating License Nos. NPF-35 and NPF-52:* Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* March 19, 2002 (67 FR 12601). The supplements dated March 4, 2002, September 12, 2002, November 20, 2002, and August 28, 2003, provided clarifying information that did not change the scope of the December 20, 2001, application or the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 10, 2003.

*No significant hazards consideration comments received:* No.

*Duke Energy Corporation, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear Station, Units 1 and 2, York County, South Carolina*

*Date of application for amendments:* January 31, 2003, as supplemented by letters dated June 12, and September 2, 2003.

*Brief description of amendments:* The amendments revise the Technical Specifications to incorporate revised means of determining the mass of ice in the ice condenser containment.

*Date of issuance:* September 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* 209 and 203.

*Facility Operating License Nos. NPF-35 and NPF-52:* Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* April 15, 2003, (68 FR 18274). The supplements dated June 12, and September 2, 2003, provided clarifying information that did not change the scope of the January 31, 2003, application nor the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 29, 2003.

*No significant hazards consideration comments received:* No.

*Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina*

*Date of application for amendments:* January 31, 2003, as supplemented by letters dated June 12, and September 2, 2003.

*Brief description of amendments:* The amendments revise the Technical Specifications to incorporate revised means of determining the mass of ice in the ice condenser containment.

*Date of issuance:* September 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* 217 and 199.

*Facility Operating License Nos. NPF-9 and NPF-17:* Amendments revised the Technical Specifications.

*Date of initial notice in **Federal Register**:* April 15, 2003, (68 FR 18274). The supplements dated June 12, and September 2, 2003, provided clarifying information that did not change the scope of the January 31, 2003, application nor the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 29, 2003.

*No significant hazards consideration comments received:* No.

*Duke Energy Corporation, Docket Nos. 50-269, 50-270, and 50-287, Oconee Nuclear Station, Units 1, 2, and 3, Oconee County, South Carolina*

*Date of application for amendments:* March 20, 2003, supplemented by letters dated July 22, and August 5, 2003.

*Brief description of amendments:* The amendments revised the Technical Specifications and the licensing basis in the Updated Safety Analysis Report to support installation of a passive low-pressure injection cross connect inside containment.

*Date of Issuance:* September 29, 2003.

*Effective date:* As of the date of issuance and shall be implemented