

Date of issuance: September 25, 2003.
Effective date: As of the date of issuance and shall be implemented within 90 days.

Amendment No.: 258.

Facility Operating License No. NPF-3: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: July 22, 2003 (68 FR 43391). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 25, 2003.

No significant hazards consideration comments received: No.

Florida Power and Light Company, et al., Docket Nos. 50-335 and 50-389, St. Lucie Plant, Unit Nos. 1 and 2, St. Lucie County, Florida

Date of application for amendments: July 18, 2002.

Brief description of amendments: These amendments revise the Technical Specifications regarding the time period that inoperable channels of the engineered safety feature actuation system can be in the bypassed or tripped condition.

Date of Issuance: September 30, 2003.

Effective Date: As of the date of issuance and shall be implemented within 60 days of issuance.

Amendment Nos.: 188 and 132.

Facility Operating License Nos. DPR-67 and NPF-16: Amendments revise the Technical Specifications.

Date of initial notice in Federal Register: August 20, 2002 (67 FR 53987). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 30, 2003.

No significant hazards consideration comments received: No.

FPL Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: October 11, 2002, as supplemented by letters dated April 21, and July 29, 2003.

Description of amendment request: The amendment revises the Technical Specifications (TS) to eliminate the Power Range Neutron Flux High Negative Rate Reactor Trip function from TS 3/4.3.1, "Reactor Trip System Instrumentation," TS 2.2.1, "Reactor Trip System Instrumentation Setpoints," and their associated Bases. The amendment also revises TS 3/4.10.3, "Physics Tests," TS 3/4.10.4, "Reactor Coolant Loops," and TS Table 4.3-1, "Reactor Trip System Instrumentation Surveillance Requirements," that are associated with certain testing activities required during STARTUP operations. The revision also

rewords the time interval for the Analog Channel Operational Test (ACOT) in surveillance requirement (SR) 4.10.3.2. In correlation with the revision to extend the ACOT interval in SR 4.10.3.2, Table 4.3-1 Note 1 is revised. This revision also extends the ACOT interval for those Functional Units that reference TS Table 4.3-1 Note 1. The revision to TS 3/4.10.4 will delete TS 3/4.10.4 in its entirety. Additionally, as a result of deleting TS 3/4.10.4, the footnote which references TS 3/4.10.4 in TS 3/4.4.1.1 is deleted as well.

Date of issuance: October 1, 2003.

Effective date: As of its date of issuance, and shall be implemented within 90 days.

Amendment No.: 91.

Facility Operating License No. NPF-86: Amendment revises the TSs.

Date of initial notice in Federal Register: November 26, 2002 (67 FR 70767). The April 21, 2003 and July 16, 2003, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the amendment beyond the scope of the initial notice. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 1, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant, Kewaunee County, Wisconsin

Date of application for amendment: September 30, 2002, as supplemented July 24 and September 25, 2003.

Brief description of amendment: The amendment authorizes changes to the Updated Safety Analysis Report (USAR) to allow the use of an upgraded computer code for design-basis accident containment integrity analyses called Generation of Thermal-Hydraulic Information for Containment (GOTHIC) version 7.0p2 (GOTHIC 7) with noted conditions.

Date of issuance: September 29, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 169.

Facility Operating License No. DPR-43: The amendment authorizes changes to the Updated Safety Analysis Report.

Date of initial notice in Federal Register: October 29, 2002 (67 FR 66011). The supplemental letters contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice. The

Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 29, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant, Kewaunee County, Wisconsin

Date of application for amendment: April 30, 2003.

Brief description of amendment: The amendment revises Kewaunee Nuclear Power Plant, Technical Specification Section 6.3, "Plant Staff Qualifications." The amendment updates requirements that have been outdated based on licensed operator training programs being accredited by the National Academy for Nuclear Training and promulgation of the revised 10 CFR 55, "Operators' Licenses."

Date of issuance: October 2, 2003.

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment No.: 170.

Facility Operating License No. DPR-43: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: June 10, 2003 (68 FR 34670). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 2, 2003.

No significant hazards consideration comments received: No.

Nuclear Management Company, LLC, Docket Nos. 50-282 and 50-306, Prairie Island Nuclear Generating Plant, Units 1 and 2, Goodhue County, Minnesota

Date of application for amendments: March 11, 2003, as supplemented July 16, 2003.

Brief description of amendments: The amendments revise Technical Specification (TS) 3.1.4, "Rod Group Alignment Limits," and TS 3.1.7, "Rod Position Indication," to add a 1-hour soak time to both TSs to allow the control rod drive mechanisms additional time following substantial rod motion to reach thermal equilibrium.

Date of issuance: October 1, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 160 and 151.

Facility Operating License Nos. DPR-42 and DPR-60: Amendments revised the TSs.

Date of initial notice in Federal Register: April 15, 2003 (68 FR 18280). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 1, 2003.