

*No significant hazards consideration comments received:* No.

*Pacific Gas and Electric Company, Docket Nos. 50-275 and 50-323, Diablo Canyon Nuclear Power Plant, Units 1 and 2, San Luis Obispo County, California*

*Date of application for amendments:* April 15, 2002, as supplemented by letters dated September 27, 2002, February 28, 2003, April 25, 2003, June 24, 2003, and September 12, 2003.

*Brief description of amendments:* The amendments authorize changes to the Final Safety Analysis Report (FSAR) Update, together with other analyses, design, and procedure changes, to implement the Diablo Canyon Power Plant NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants" program that is required to implement a dry cask Independent Spent Fuel Storage Installation (ISFSI).

*Date of issuance:* September 26, 2003.

*Effective date:* September 26, 2003, and shall be implemented following the implementation of the ISFSI. The implementation of the amendments include the incorporation into the FSAR Update the changes discussed above, as described in the licensee's application dated April 15, 2002; its supplements dated September 27, 2002, February 28, 2003, April 25, 2003, June 24, 2003, and September 12, 2003; and evaluated in the staff's safety evaluation attached to the amendment.

*Amendment Nos.:* 162 and 163.

*Facility Operating License Nos. DPR-80 and DPR-82:* The amendments authorized revision of the FSAR Update.

*Date of initial notice in Federal Register:* June 11, 2002 (67 FR 40025) The supplemental letters dated September 27, 2002, February 28, 2003, April 25, 2003, June 24, 2003, and September 12, 2003, provided additional clarifying information, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 26, 2003.

*No significant hazards consideration comments received:* No.

*PSEG Nuclear, LLC, Docket Nos. 50-272 and 50-311, Salem Nuclear Generating Station, Unit Nos. 1 and 2, Salem County, New Jersey*

*Date of application for amendments:* April 10, 2003.

*Brief description of amendments:* The amendments revise Salem Nuclear Generating Station, Unit Nos. 1 and 2

(Salem), Technical Specifications (TSs) Table 3.3-1, "Reactor Trip System Instrumentation," by modifying the "Condition and Setpoint" description of permissive interlock "P-7." The phrase "Turbine impulse chamber pressure," contained in the "Condition and Setpoint" description for permissive P-7, is replaced with the phrase "Turbine steam line inlet pressure" in order to support planned modifications to Salem's high pressure turbines.

*Date of issuance:* October 1, 2003.

*Effective date:* As of the date of issuance, and shall be implemented within 30 days.

*Amendment Nos.:* 259 and 240.

*Facility Operating License Nos. DPR-70 and DPR-75:* The amendments revised the TSs.

*Date of initial notice in Federal Register:* June 10, 2003 (68 FR 34672). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 1, 2003.

*No significant hazards consideration comments received:* No.

*South Carolina Electric & Gas Company, South Carolina Public Service Authority, Docket No. 50-395, Virgil C. Summer Nuclear Station, Unit No. 1, Fairfield County, South Carolina*

*Date of application for amendment:* September 24, 2002, supplemented by letters dated April 8 and May 21, 2003.

*Brief description of amendment:* This amendment revises the Action Statement and surveillance requirements for the emergency diesel generators (EDGs). The proposed changes would revise TS Section 3.8.1.1, Action b.2 and Action c.2, and TS Section 4.8.1.1, "AC Sources" and associated Bases Section related to the EDG.

*Date of issuance:* September 26, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment No.:* 164.

*Facility Operating License No. NPF-12:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* November 12, 2002 (67 FR 68742). The April 8 and May 21, 2003, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the scope of the application. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 26, 2003.

*No significant hazards consideration comments received:* No.

*Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant, Units 1 and 2, Appling County, Georgia*

*Date of application for amendments:* December 19, 2002, as supplemented by letters dated April 7, May 21, May 30, June 4, September 4, and September 12, 2003.

*Brief description of amendments:* The amendments revise the licensed power level for Hatch, Units 1 and 2 by 1.5 percent from 2763 megawatts thermal (MWt) to 2804 MWt. The change is based on the installation of the Advanced Measurement Analysis Group, Inc. (AMAG)/Westinghouse Crossflow ultrasonic flow measurement instrumentation, resulting in improved feedwater flow measurement accuracy. The amendment changes the Renewed Facility Operating License (RFOL) and the Technical Specifications (TSs) to reflect the increased licensed power level.

*Date of issuance:* September 23, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 90 days from the date of issuance.

*Amendment Nos.:* 238 and 180.

*Renewed Facility Operating License Nos. DPR-57 and NPF-5:* Amendments revise the RFOL and the TSs.

*Date of initial notice in Federal Register:* February 18, 2003 (68 FR 7821). The supplements dated April 7, May 21, May 30, June 4, September 4, and September 12, 2003, provided clarifying information that did not change the scope of the December 19, 2002, application nor the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 23, 2003.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket No. 50-390, Watts Bar Nuclear Plant, Unit 1, Rhea County, Tennessee*

*Date of application for amendment:* February 14, 2003, as supplemented by letters dated June 5 and August 21, 2003.

*Brief description of amendment:* The amendment consists of changes to Technical Specification (TS) 5.9.5, "Core Operating Limits Report (COLR)." The revised TS modifies TS 5.9.5 to add three additional methodologies in support of the Westinghouse 17x17