

Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, located at One White Flint North, Public File Area 01F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by email to pdr@nrc.gov.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station, Units 2 and 3, Grundy County, Illinois

Date of application for amendments: December 20, 2002, as supplemented by letter dated May 30, 2003.

Brief description of amendments: The amendments modify the basis for licensee's compliance with the requirements of Appendix H to 10 CFR 50, "Reactor Vessel Material Surveillance Program Requirements" for Dresden Units 2 and 3. The amendment approves the licensee to implement the Boiling Water Reactor Vessel and Internals Project reactor pressure vessel integrated surveillance program.

Date of issuance: September 29, 2003.

Effective date: As of the date of issuance and shall be implemented prior to the next reactor vessel surveillance capsule removal.

Amendment Nos.: 202/194.

Facility Operating License Nos. DPR-19 and DPR-25: The amendments revised the Facility Operating Licenses and the Update Final Safety Analysis Report.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5669). The May 30, 2003, submittal provided additional clarifying information that did not change the initial proposed no significant hazards consideration. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated September 29, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station, Units 2 and 3, Grundy County, Illinois

Docket Nos. 50-254 and 50-265, Quad Cities Nuclear Power Station, Units 1 and 2, Rock Island County, Illinois

Date of application for amendments: February 14, 2003, as supplemented by letter dated August 8, 2003.

Brief description of amendments: The amendments relax the Technical Specifications (TSs) surveillance requirement (SR) for reactor instrumentation line excess flow check valves (EFCVs). Currently, TSs require testing of each reactor instrumentation line EFCV on a 24 month frequency. The proposed TS SR requires that a representative sample of reactor instrumentation line EFCVs be tested every 24 months, such that each EFCV will be tested nominally once every 10 years.

Date of issuance: October 10, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 203/195, 218/212.

Facility Operating License Nos. DPR-19, DPR-25, DPR-29 and DPR-30. The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: May 13, 2003 (68 FR 25654). The August 8, 2003, submittal provided additional clarifying information that did not change the initial proposed no significant hazards consideration. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 10, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station, Units 2 and 3, Grundy County, Illinois

Date of application for amendments: February 26, 2003.

Brief description of amendments: The amendments authorize changes to the Updated Final Safety Analysis Report (UFSAR) to describe a load drop analysis performed for handling reactor cavity shield blocks weighing greater than 110 tons with the Unit 2/3 reactor building crane during power operation.

Date of issuance: October 10, 2003.

Effective date: As of the date of issuance and shall be implemented prior to handling reactor cavity shield blocks weighing greater than 110 tons with the Unit 2/3 reactor building crane for refueling outage D2R18.

Amendment Nos.: 204 and 196.

Facility Operating License Nos. DPR-19 and DPR-25: The amendments revised the UFSAR.

Date of initial notice in Federal Register: June 24, 2003 (68 FR 37576). The June 12, July 25, September 11, and October 9, 2003, submittals provided additional clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 10, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, and PSEG Nuclear LLC, Docket No. 50-278, Peach Bottom Atomic Power Station, Unit 3, York and Lancaster Counties, Pennsylvania

Date of application for amendments: June 23, 2003, as supplemented September 4, 2003.

Brief description of amendment: The amendment revised the Technical Specifications for the safety limit minimum critical power ratio.

Date of issuance: October 3, 2003.

Effective date: As of date of issuance and shall be implemented prior to startup for Cycle 15 operations, scheduled for October 2003.

Amendment No.: 252.

Facility Operating License No. DPR-56: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 5, 2003 (68 FR 46243). The September 4, 2003, letter provided information that did not change the initial proposed no significant hazards consideration determination or expand the application beyond the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 3, 2003.

No significant hazards consideration comments received: No.

FirstEnergy Nuclear Operating Company, Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit 1, Ottawa County, Ohio

Date of application for amendment: April 1, 2001, as supplemented by letters dated April 30, and May 6, 2003.

Brief description of amendment: The proposed changes involve Technical Specification (TS) 3/4.3.1, "Reactor Protection System (RPS) Instrumentation," TS 3/4.3.2.1, "Safety Features Actuation System (SFAS) Instrumentation," and TS 3/4.3.2.2, "Steam and Feedwater Rupture Control System (SFRCS) Instrumentation." The