

Requirements Manual (SSTR). The amendment also revises TS 3.1.2.7, "Reactivity Control Systems-Boration Systems-Isolation of Unborated Water Sources-Shutdown."

The amendment also revises TSs 3.4.1.2, "Reactor Coolant System-Reactor Coolant Loops and Coolant Recirculation-Hot Standby;" 3.4.3, "Reactor Coolant System-Pressurizer;" 3.4.7, "Reactor Coolant System-Chemistry;" and 3.9.2, "Refueling Operations-Instrumentation," to adopt wording that more closely resembles NUREG-1431, Revision 2, "Standard Technical Specifications." The revision to TS 3/4.9.2 also involves surveillance changes. The associated Bases have been modified as a result of the changes.

Date of issuance: October 3, 2003.

Effective date: As of its date of issuance, and shall be implemented within 60 days.

Amendment No.: 93.

Facility Operating License No. NPF-86: The amendment revised the TSs.

Date of initial notice in Federal Register: December 10, 2002 (67 FR 75880). The May 29, 2003, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the amendment beyond the scope of the initial notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 3, 2003.

No significant hazards consideration comments received: No.

FPL Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: October 11, 2002, as supplemented by letters dated May 30, 2003 (two letters), July 16, 2003, August 18, 2003, September 9, 2003, and September 15, 2003.

Description of amendment request: The amendment revises Technical Specification (TS) 3/4.9.4, "Containment Building Penetrations," to permit the equipment hatch to be open during core alterations and/or during movement of irradiated fuel assemblies within containment. Specifically, the applicability of the TS would be modified to apply only to the movement of recently irradiated fuel assemblies. Recently irradiated fuel assemblies would be described in the bases as fuel that has occupied part of a critical reactor core within the past 80 hours.

Date of issuance: October 3, 2003.

Effective date: As of its date of issuance, and shall be implemented within 60 days.

Amendment No.: 94.

Facility Operating License No. NPF-86: Amendment revises the TS.

Date of initial notice in Federal Register: November 26, 2002 (67 FR 70766). The May 30, 2003, July 16, 2003, August 18, 2003, September 9, 2003, and September 15, 2003, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination nor expand the amendment beyond the scope of the initial notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 3, 2003.

No significant hazards consideration comments received: No.

FPL Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: October 11, 2002, as supplemented by letters dated July 16, 2003, July 17, 2003, August 18, 2003, August 25, 2003, September 9, 2003, and September 15, 2003.

Description of amendment request: The amendment revises Technical Specification (TS) 3/4.9.3, "Decay Time," reducing the minimum time irradiated fuel must decay after occupying part of a critical core from 100 to 80 hours.

Date of issuance: October 3, 2003.

Effective date: As of its date of issuance, and shall be implemented within 60 days.

Amendment No.: 95.

Facility Operating License No. NPF-86: Amendment revises the TS.

Date of initial notice in Federal Register: November 26, 2002 (67 FR 70767). The July 16, 2003, July 17, 2003, August 18, 2003, August 25, 2003, September 9, 2003, and September 15, 2003, letters provided clarifying information that did not change the initial proposed no significant hazards consideration determination nor expand the amendment beyond the scope of the initial notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 3, 2003.

No significant hazards consideration comments received: No.

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C. Cook Nuclear Plant, Units 1 and 2, Berrien County, Michigan

Date of application for amendments: September 3, 2003.

Brief description of amendments: The amendments revise Technical Specification (TS) Limiting Condition for Operation (LCO) 3.6.5.1.d to replace

the phrase "Each ice basket" with the phrase "Ice baskets." This change makes the LCO consistent with associated TS Surveillance Requirement (SR) 4.6.5.1.b.2 and allows the SR to define the detailed requirements for ice basket weight.

Date of issuance: October 10, 2003.

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment Nos.: 280 and 262.

Facility Operating License Nos. DPR-58 and DPR-74: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: September 10, 2003 (68 FR 53402). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 10, 2003.

No significant hazards consideration comments received: No.

PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: July 3, 2003, as supplemented by letters dated September 9 and 23, 2003.

Brief description of amendments: These amendments revised the Technical Specifications, Section 3.8.1, "AC [alternating current] Sources—Operating," to extend the allowable Completion Time for Required Actions for one offsite circuit inoperable, from 72 hours to 10 days on a one-time basis.

Date of issuance: October 10, 2003.

Effective date: Upon issuance and shall be implemented by October 31, 2003.

Amendment Nos.: 214 and 189.

Facility Operating License Nos. NPF-14 and NPF-22: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: July 22, 2003. (68 FR 43392). The supplemental letters dated September 9 and 23, 2003, provided clarifying information that did not expand the scope of the requested action as described in the initial **Federal Register** notice, and did not change the staff's proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 10, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket No. 50-390, Watts Bar Nuclear Plant, Unit 1, Rhea County, Tennessee

Date of application for amendment: May 14, 2003, as supplemented June 24, 2003.