

Brief description of amendment: The amendment revised Technical Specification (TS) 3.3.1, "Reactor Trip System Instrumentation," and TS 3.4.1, "RCS [Reactor Coolant System] Pressure, Temperature, and Flow DNB [Departure from Nucleate Boiling] Limits." The revised TS allows the measurement of RCS flow using the elbow flow tap methodology as an alternative to the current flow calorimetric method.

Date of issuance: October 3, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 47.

Facility Operating License No. NPF-90: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: June 24, 2003 (68 FR 37584). The supplemental letter provided clarifying information that did not expand the scope of the original request and did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 3, 2003.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket No. 50-390, Watts Bar Nuclear Plant, Unit 1, Rhea County, Tennessee

Date of application for amendment: May 30, 2003, as supplemented August 18, September 10, September 30, and October 3, 2003.

Brief description of amendment: The amendment revised Technical Specification (TS) 3.5.1, "Accumulators," TS 3.5.4, "Refueling Water Storage Tank (RWST)" and TS 4.2.1, "Fuel Assemblies," to revise the minimum and maximum accumulator and RWST boron concentration and to limit the maximum number of tritium producing burnable absorber rods (TPBARs) that can be loaded into the reactor core accordingly. The requested change would also add the cycle-specific number of TPBARs to the Core Operating Limits Report. The licensee is revising the corresponding TS Bases pages.

Date of issuance: October 8, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 48.

Facility Operating License No. NPF-90: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: July 8, 2003 (68 FR 40720). The supplemental letters provided clarifying

information that did not expand the scope of the original request and did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 8, 2003.

No significant hazards consideration comments received: No.

TXU Generation Company LP, Docket Nos. 50-445 and 50-446, Comanche Peak Steam Electric Station, Unit Nos. 1 and 2, Somervell County, Texas

Date of amendment request: July 10, 2003, as supplemented by letter dated August 28, 2003.

Brief description of amendments: The amendments revise the Technical Specification (TS) reflecting approval of a one-time extension for each unit of allowable outage time for restoring the operability of control room emergency filtration system boundary.

Date of issuance: October 2, 2003.

Effective date: As of the date of issuance. The TS shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 108 and 108.

Facility Operating License Nos. NPF-87 and NPF-89: The amendments revised the TS.

Date of initial notice in Federal Register: August 5, 2003 (68 FR 46246)

The August 28, 2003, supplemental letter provided clarifying information and did not change the scope of the original **Federal Register** notice or the staff's original no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 2, 2003.

No significant hazards consideration comments received: No.

Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway County, Missouri

Date of application for amendment: October 3, 2002.

Brief description of amendment: The amendment revises Tables 3.3.1-1 (Reactor Trip System (RTS) Instrumentation) and 3.3.2-1 (Engineered Safety Feature Actuation System (ESFAS) Instrumentation) of Limiting Conditions for Operation 3.3.1, "RTS Instrumentation," and 3.3.2, "ESFAS Instrumentation," of the TSs. The revisions are for the SG water level low-low (adverse and normal containment environment) functions.

Date of issuance: October 2, 2003.

Effective date: October 2, 2003, and shall be implemented within 60 days of the date of issuance.

Amendment No.: 157.

Facility Operating License No. NPF-30: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 26, 2003 (67 FR 70770). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 2, 2003.

No significant hazards consideration comments received: No.

Virginia Electric and Power Company, et al., Docket Nos. 50-280 and 50-281, Surry Power Station, Units 1 and 2, Surry County, Virginia

Date of application for amendments: November 5, 2002, as supplemented February 14 and June 9, 2003.

Brief Description of amendments: These amendments revise the technical specifications to delete the monthly analog rod position test for the control rod bottom bistables.

Date of issuance: October 1, 2003.

Effective date: As of the date of issuance, and shall be implemented within 30 days.

Amendment Nos.: 237 and 236.

Renewed Facility Operating License Nos. DPR-32 and DPR-37: Amendments change the Technical Specifications surveillance requirements.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5683). The February 14 and June 9, 2003, supplements contained clarifying information only and did not change the initial proposed no significant hazards consideration determination or expand the scope of the initial application.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 1, 2003.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 20th day of October, 2003.

For the Nuclear Regulatory Commission.

Ledyard B. Marsh,

Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 03-26890 Filed 10-27-03; 8:45 am]

BILLING CODE 7590-01-P

POSTAL SERVICE

Flat Mail Identification Code System (FICS)

ACTION: Notice.

AGENCY: Postal Service.

SUMMARY: This notice announces a new system that the United States Postal Service (USPS) plans to deploy for