

Safety Evaluation dated October 21, 2003.

No significant hazards consideration comments received: No.

**Entergy Operations, Inc., System Energy Resources, Inc., South Mississippi Electric Power Association, and Entergy Mississippi, Inc., Docket No. 50-416, Grand Gulf Nuclear Station, Unit 1, Claiborne County, Mississippi**

*Date of application for amendment:* May 12, 2003, as supplemented by letter dated August 7, 2003.

*Brief description of amendment:* The amendment would revise the Technical Specifications to remove the MODE restrictions for performance of Surveillance Requirements 3.8.4.7 and 3.8.4.8 for the Division 3 direct current electrical power subsystem.

*Date of issuance:* October 27, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment No.:* 159.

*Facility Operating License No. NPF-29:* The amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* June 10, 2003 (68 FR 34665). The August 7, 2003, supplemental letter provided clarifying information that did not change the scope of the original Federal Register notice or the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 27, 2003.

No significant hazards consideration comments received: No.

**Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant, Units 3 and 4, Miami-Dade County, Florida**

*Date of application for amendments:* December 20, 2002, as supplemented August 15, 2003.

*Brief description of amendments:* The amendments provide editorial and administrative changes to the Technical Specifications. The changes correct typographical, spelling, numbering syntax, page break, and font consistency errors as well as removing blank pages and associated references. There are no substantive changes made in the proposed amendment.

*Date of issuance:* October 21, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment Nos.:* 224 and 219.

*Renewed Facility Operating License Nos. DPR-31 and DPR-41:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* February 4, 2003 (68 FR 5677). The supplemental letter provided clarifying information that was within the scope of the initial notice and did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in an Environmental Assessment dated October 17, 2003, and a Safety Evaluation dated October 21, 2003.

No significant hazards consideration comments received: No.

**GPU Nuclear Inc., Docket No. 50-320, Three Mile Island Nuclear Station, Unit 2, Dauphin County, Pennsylvania**

*Date of amendment request:* July 21, 2003.

*Brief description of amendment request:* The amendment revises the technical specification (TS) administrative controls to make the Three Mile Island (TMI) Unit 2 radioactive effluent control program consistent with the program for the TMI Unit 1 operating reactor TS. The proposed change adopts the TMI Unit 1 liquid discharge limits since both Units 1 and 2 use the same liquid discharge monitor and have a common discharge pathway. The gaseous discharge limits will also be updated to reflect the current 10 CFR 20 nomenclature along with some minor editorial changes. Additionally, the definition of a member of the public will be made consistent with the definition in 10 CFR 20.

*Date of issuance:* October 20, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days.

*Amendment No.:* 60.

*Facility Operating License No. DPR-73:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* September 18, 2003 (68 FR 54750).

The Commission's related evaluation of the amendment is contained in a safety evaluation dated October 20, 2003.

No significant hazards consideration comments received: No.

**Nine Mile Point Nuclear Station, LLC, Docket No. 50-220, Nine Mile Point Nuclear Station, Unit No. 1, Oswego County, New York**

*Date of application for amendment:* November 15, 2002, as supplemented by letters dated January 15, July 31, and September 15, 2003.

*Brief description of amendment:* The amendment revised the reactor coolant system pressure-temperature limit

curves and tables in Section 3/4.2.2, "Minimum Reactor Vessel Temperature for Pressurization," of the Technical Specifications. The revised curves and tables are effective up to 28 effective full-power years.

*Date of issuance:* October 27, 2003.

*Effective date:* October 27, 2003, to be implemented within 60 days.

*Amendment No.:* 183.

*Facility Operating License No. DPR-63:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* December 10, 2002 (67 FR 75882).

The supplemental letters of January 15, July 31, and September 15, 2003, provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 27, 2003.

No significant hazards consideration comments received: No.

**Nuclear Management Company, LLC, Docket No. 50-255, Palisades Plant, Van Buren County, Michigan**

*Date of application for amendment:* April 30, 2003.

*Brief description of amendment:* The amendment revises Technical Specification Section 5.3, "Plant Staff Qualifications," to update requirements that have been outdated based on licensed operator training programs being accredited by the National Academy for Nuclear Training and promulgation of the revised 10 CFR Part 55, "Operators" Licenses."

*Date of issuance:* October 24, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 45 days.

*Amendment No.:* 212.

*Facility Operating License No. DPR-20:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* June 10, 2003 (68 FR 34670).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 24, 2003.

No significant hazards consideration comments received: No.

**Nuclear Management Company, LLC, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Units 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin**

*Date of application for amendments:* October 17, 2002.

*Brief description of amendments:* The amendment revises Technical