

clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 4, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, and PSEG Nuclear LLC,

Docket Nos. 50-277 and 50-278, Peach Bottom Atomic Power Station, Units 2 and 3, (PBAPS-2 and 3) York County and Lancaster County, Pennsylvania.

Date of application for amendments: December 20, 2002, as supplemented May 30, 2003.

Brief description of amendments: The amendments revised the Updated Final Safety Analysis Report (UFSAR) for Peach Bottom Atomic Power Station, Units 2 and 3, by allowing implementation of the Boiling Water Reactor Vessel and Internals Project reactor pressure vessel integrated surveillance program as the basis for demonstrating the compliance with the requirements of Appendix H, "Reactor Vessel Material Surveillance Program Requirements," to Title 10 of the Code of Federal Regulations, Part 50.

Date of issuance: November 4, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment Nos.: 249 and 253.

Renewed Facility Operating License Nos. DPR-44 and DPR-56: The amendments authorized changes to the UFSAR for PBAPS-2 and 3.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5669). The supplement dated May 30, 2003, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 4, 2003.

No significant hazards consideration comments received: No.

Indiana Michigan Power Company, Docket No. 50-316, Donald C. Cook Nuclear Plant, Unit 2, Berrien County, Michigan.

Date of application for amendment: March 27, 2003, as supplemented August 15, 2003.

Brief description of amendment: The amendment lowers the trip setpoint and allowable value contained in Technical Specification (TS) Table 3.3-4 for the

pressurizer pressure low safety injection signal. The amendment also lowers the value for the P-11 setpoint in TS Table 3.3-3. These changes increase the margin between the low pressurizer pressure safety injection actuation setpoint and the minimum pressurizer pressure that occurs immediately following a reactor trip.

Date of issuance: November 12, 2003.

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment No.: 263.

Facility Operating License No. DPR-74: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: May 27, 2003 (68 FR 28853).

The supplemental letter contained clarifying information and did not change the initial no significant hazards consideration determination and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 12, 2003.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska.

Date of amendment request: December 31, 2002, as supplemented by letter dated July 24, 2003.

Brief description of amendment: The amendment revises the Updated Safety Analysis Report (USAR) reflecting a change of the reactor vessel material surveillance program to incorporate the Boiling Water Reactor Vessel and Internals Project Integrated Surveillance Program into the licensing basis.

Date of issuance: October 31, 2003.

Effective date: As of the date of issuance. The amendment shall be implemented within 30 days of issuance and the USAR changes shall be implemented in the next periodic update to the USAR in accordance with 10 CFR 50.71(e).

Amendment No.: 201.

Facility Operating License No. DPR-46: Amendment revised the USAR.

Date of initial notice in Federal Register: February 4, 2003 (68 FR 5678).

The July 24, 2003, supplemental letter provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register** on February 4, 2003 (68 FR 5678).

The Commission's related evaluation of the amendment is contained in a

Safety Evaluation dated October 31, 2003.

No significant hazards consideration comments received: No.

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska.

Date of amendment request: January 27, 2003, as supplemented by letter dated August 1, 2003.

Brief description of amendment: The amendment authorizes revisions to the Updated Safety Analysis Report (USAR) to incorporate the NRC approval of the GOTHIC 7.0 computer program for performing containment analyses.

Date of issuance: November 5, 2003.

Effective date: November 5, 2003, and shall be implemented within 30 days of the date of issuance. The implementation of the amendment includes the incorporation into the USAR the changes discussed above, as described in the licensee's application dated January 27, 2003, and supplement dated August 1, 2003, and evaluated in the staff's Safety Evaluation attached to the amendment.

Amendment No.: 222.

Renewed Facility Operating License No. DPR-40: The amendment revised the USAR.

Date of initial notice in Federal Register: March 18, 2003 (68 FR 12956).

The August 1, 2003, supplemental letter provided additional clarifying information, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 5, 2003.

No significant hazards consideration comments received: No.

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska.

Date of amendment request: January 27, 2003, as supplemented by letter dated October 14, 2003.

Brief description of amendment: The amendment deletes Technical Specification (TS) 2.3(2)i and the corresponding Bases that allows the performance of the surveillance test of Table 3-2, Item 20 (Recirculation Actuation Logic Channel Functional Test) under administrative controls, while components in excess of those allowed by Conditions a, b, d, and e of TS 2.3(2) are inoperable, provided they are returned to operable status within one hour. This allowance was granted in Amendment No. 206 issued April 19, 2002, and only applied until the end of Cycle 21.