

Calvert Cliffs Nuclear Power Plant, Inc., Docket Nos. 50-317 and 50-318, Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, Calvert County, Maryland

Date of application for amendments: May 28, 2003, as supplemented November 25, 2003.

Brief description of amendments: These amendments changed the reactor pressure vessel pressure-temperature limit cooldown curves in the Calvert Cliffs 1 and 2 Technical Specifications by incorporating a different range of temperatures for which a maximum cooldown rate of 100°F/hr is acceptable.

Date of issuance: December 9, 2003.

Effective date: As of the date of issuance to be implemented within 120 days.

Amendment Nos.: 261 and 238.

Renewed Facility Operating License Nos. DPR-53 and DPR-69: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: July 8, 2003 (68 FR 40701).

The November 25, 2003, supplemental letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of these amendments is contained in a Safety Evaluation dated December 9, 2003.

No significant hazards consideration comments received: No.

Entergy Gulf States, Inc., and Entergy Operations, Inc., Docket No. 50-458, River Bend Station, Unit 1, West Feliciana Parish, Louisiana.

Date of amendment request: March 14, 2003, as supplemented by letter dated June 24, 2003.

Brief description of amendment: The amendment revises Technical Specification (TS) 3.8.1, "AC Sources—Operating," Surveillance Requirements (SRs) pertaining to the testing of the Division 1 and 2 standby diesel generators (DGs). Specifically, the proposed changes eliminate mode restrictions that previously prevented performance of SRs during Modes 1 and 2 for the Division 1 and 2 DGs. The changes allow the performance of SR 3.8.1.9 and SR 3.8.1.10 for the Division 1 and 2 DGs during any plant operating mode.

Date of issuance: November 7, 2003.

Effective date: As of the date of issuance and shall be implemented 30 days from the date of issuance.

Amendment No.: 137.

Facility Operating License No. NPF-47: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: (68 FR 18275). The June 24,

2003, supplemental letter provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 7, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Operations, Inc., Docket No. 50-286, Indian Point Nuclear Generating Unit No. 3, Westchester County, New York

Date of application for amendment: May 28, 2003, as supplemented on June 24, 2003.

Brief description of amendment: The amendment revised Technical Specification (TS) Section 3.4.3, "RCS Pressure and Temperature (P/T) Limits," and section 3.4.12, "Low Temperature Overpressure Protection (LTOP)," to incorporate revised reactor pressure vessel P/T limits and overpressure protection system limits to allow operation up to 20 effective full-power years. Specifically, the amendment changed TS Figures 3.4.3-1 to 3.4.3-3 and TS Figures 3.4.12-1 to 3.4.12-4.

Date of issuance: December 3, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 220.

Facility Operating License No. DPR-64: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: July 22, 2003 (68 FR 43389).

The June 24 letter provided clarifying information that did not enlarge the scope of the amendment request or change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 3, 2003.

No significant hazards consideration comments received: No.

Entergy Operations, Inc., Docket No. 50-368, Arkansas Nuclear One, Unit No. 2, Pope County, Arkansas

Date of application for amendment: May 1, 2003, as supplemented by letter dated September 30, 2003.

Brief description of amendment: The amendment modifies the surveillance testing requirements for the containment spray system by deleting the requirement to verify the position of valves that are locked, sealed, or otherwise secured in their correct

position (and by deleting wording regarding the verified valves being positioned to take suction from the refueling water tank), and replacing the quantitative allowable pump degradation value with a requirement to verify the pumps perform in accordance with the Inservice Testing Program.

Date of issuance: December 4, 2003.

Effective date: As of the date of issuance to be implemented within 60 days from the date of issuance.

Amendment No.: 252.

Facility Operating License No. NPF-6: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: May 27, 2003 (68 FR 28851).

The September 30, 2003, supplemental letter provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 4, 2003.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-237 and 50-249, Dresden Nuclear Power Station (DNPS), Units 2 and 3, Grundy County, Illinois

Date of application for amendments: February 27, 2003, as supplemented on July 17, July 31, September 11, and November 25, 2003.

Brief description of amendments: The amendments revise Technical Specification Section 3.4.9, "Reactor Coolant System Pressure and Temperature (P/T) Limits," incorporating revisions to the P/T limit curves. The amendment also deletes the license conditions specified in DNPS Unit 2 Facility Operating License Section 2.C(8) and DNPS Unit 3 Facility Operating License Section 3.P, "Pressure-Temperature Limit Curves."

Date of issuance: November 26, 2003.

Effective date: As of the date of issuance and shall be implemented within 30 days of the date of issuance.

Amendment Nos.: 205/197.

Facility Operating License Nos. DPR-19 and DPR-25: The amendments revised the Facility Technical Specifications and license conditions specified in the Facility Operating Licenses.

Date of initial notice in Federal Register: August 5, 2003 (68 FR 46242).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 26, 2003.

No significant hazards consideration comments received: No.