

*Exelon Generation Company, LLC, Docket Nos. 50-352 and 50-353, Limerick Generating Station, Units 1 and 2, Montgomery County, Pennsylvania*

*Date of application for amendments:* November 26, 2002.

*Brief description of amendments:* These amendments revised TS 3.1.3.1, "Control Rod Operability," by adding new Limiting Condition for Operation criteria and applicable ACTION requirements for scram discharge volume (SDV) vent and drain valves. The changes also modified TS 3.6.3, "Primary Containment Isolation Valves," to clarify the relationship between TS 3.1.3.1 and TS 3.6.3 regarding SDV vent and drain valves.

*Date of issuance:* November 26, 2003.

*Effective date:* As of date of issuance and shall be implemented within 60 days.

*Amendment Nos.:* 168 and 131.

*Facility Operating License Nos. NPF-39 and NPF-85:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 7, 2003 (68 FR 803).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 26, 2003.

No significant hazards consideration comments received: No.

*FirstEnergy Nuclear Operating Company, et al., Docket Nos. 50-334 and 50-412, Beaver Valley Power Station, Unit Nos. 1 and 2, Beaver County, Pennsylvania*

*Date of application for amendments:* March 26, 2003.

*Brief description of amendments:* These amendments modify Technical Specifications (TSs) 4.0.1 and 4.0.3 to be consistent with the Improved Standard Technical Specifications. The amendments also modify the TS requirements for missed surveillances in TS 4.0.3 to be consistent with the Nuclear Regulatory Commission-approved Technical Specification Task Force (TSTF), Standard Technical Specification Change TSTF-358, Revision 6.

*Date of issuance:* November 25, 2003.

*Effective date:* As of the date of its issuance and shall be implemented within 60 days.

*Amendment Nos.:* 258 and 140.

*Facility Operating License Nos. DPR-66 and NPF-73:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* June 24, 2003 (68 FR 37577).

The Commission's related evaluation of the amendments is contained in a

Safety Evaluation dated November 25, 2003.

No significant hazards consideration comments received: No.

*Southern California Edison Company, et al., Docket Nos. 50-361 and 50-362, San Onofre Nuclear Generating Station, Units 2 and 3, San Diego County, California*

*Date of application for amendments:* December 9, 2002, as supplemented by letter dated August 28, 2003.

*Brief description of amendments:* The changes would revise Technical Specification (TS) 3.75, "Auxiliary Feedwater System," Surveillance Requirement (SR) 3.7.5.2 Frequency. Specifically, the wording of the Frequency of SR 3.7.5.2 would change from "31 days on a Staggered Test Basis" to "In accordance with the Inservice Testing Program." This change is requested to implement recommendations of the Standard Technical Specifications for Combustion Engineering Plants, NUREG-1432, Revision 2.

*Date of issuance:* November 25, 2003.

*Effective date:* November 25, 2003, to be implemented within 60 days of issuance.

*Amendment Nos.:* Unit 2—191; Unit 3—182.

*Facility Operating License Nos. NPF-10 and NPF-15:* The amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* January 7, 2003 (68 FR 812).

The August 28, 2003, supplemental letter provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 25, 2003.

No significant hazards consideration comments received: No.

*STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas*

*Date of amendment request:* November 14, 2002, as supplemented by letters dated October 30, and November 6, 2003.

*Brief description of amendments:* The amendments revise the Updated Final Safety Analysis Report (UFSAR) to eliminate the turbine missile design basis.

*Date of issuance:* December 2, 2003.

*Effective date:* As of the date of issuance and shall be implemented

within 30 days of issuance. The UFSAR changes shall be implemented in the next periodic update to the UFSAR in accordance with 10 CFR 50.71(e).

*Amendment Nos.:* Unit 1—158; Unit 2—146.

*Facility Operating License Nos. NPF-76 and NPF-80:* The amendments revised the UFSAR.

*Date of initial notice in Federal Register:* February 18, 2003 (68 FR 7821).

The October 30, and November 6, 2003, supplemental letters provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination as published in the **Federal Register** on February 18, 2003 (68 FR 7821).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 2, 2003.

No significant hazards consideration comments received: No.

*STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas*

*Date of amendment request:* May 22, 2003, as supplemented by letters dated September 10 and September 30, 2003.

*Brief description of amendments:* The amendments change the pressurizer safety valve lift tolerance, as specified in Technical Specification (TS) 3.4.2.2, "Reactor Coolant System," from plus/minus ( $\pm$ ) 2 percent (%) to +2% and -3%.

*Date of issuance:* December 2, 2003.

*Effective date:* As of the date of issuance and shall be implemented within 30 days of issuance.

*Amendment Nos.:* Unit 1—159; Unit 2—147.

*Facility Operating License Nos. NPF-76 and NPF-80:* The amendments revised the TSs.

*Date of initial notice in Federal Register:* June 24, 2003 (68 FR 37583).

The September 10 and September 30, 2003, supplemental letters provided clarifying information that was within the scope of the original **Federal Register** notice (68 FR 37583) and did not change the initial no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 2, 2003.

No significant hazards consideration comments received: No.