

Connecticut Yankee Atomic Power Company, Docket No. 50-213, Haddam Neck Plant, Middlesex County, Connecticut

Date of amendment request: May 29, 2001, and its supplements dated August 29, 2001, and September 24, 2002.

Brief description of amendment: The amendment revises paragraph 2.C.(5), "Physical Protection," of Facility Operating License No. DPR-61 to reference the Defueled Physical Security Plan that includes the security plan for the Independent Spent Fuel Storage Installation.

Date of issuance: January 30, 2003.

Effective date: January 30, 2003, and shall be implemented within 30 days from the date of issuance and prior to the transfer of spent nuclear fuel to the Independent Spent Fuel Storage Installation.

Amendment No.: 199.

Facility Operating License No. DPR-61: The amendment revised the Operating License.

Date of initial notice in Federal Register: August 22, 2001 (66 FR 44163). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 30, 2003.

No significant hazards consideration comments received: No.

Detroit Edison Company, Docket No. 50-341, Fermi 2, Monroe County, Michigan

Date of application for amendment: August 8, 2002, as supplemented October 23, 2002.

Brief description of amendment: The amendment authorized changes to the Updated Final Safety Analysis Report (USFAR) for Fermi 2 by allowing implementation of the Boiling Water Reactor Vessel and Internals Project reactor pressure vessel Integrated Surveillance Program as the basis for demonstrating the compliance with the requirements of Appendix H, "Reactor Vessel Material Surveillance Program Requirements," to 10 CFR part 50.

Date of issuance: January 30, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 152.

Facility Operating License No. NPF-43: Amendment authorizes changes to the USFAR.

Date of initial notice in Federal Register: September 3, 2002 (67 FR 56320). The October 23, 2002, supplemental letter provided additional clarifying information that did not change the original no significant hazards consideration determination or

expand the amendment beyond the scope of the original notice. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 30, 2003.

No significant hazards consideration comments received: No.

Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: April 18, 2002, as supplemented August 7, and October 9 and October 30, 2002, and January 15, 2003.

Brief description of amendments: The amendments revised Technical Specification (TS) 3.7.15 in response to Boraflex degradation to provide revised spent fuel pool (SFP) storage criteria, and revised fuel enrichment and burnup requirements that take credit for soluble boron. TS 4.3.1 is revised to increase the required soluble boron credit from a concentration of 730 parts per million (ppm) to 850 ppm to ensure acceptable levels of subcriticality in the SFPs. Associated changes to the TS Bases are also included.

Date of issuance: February 4, 2003.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment Nos.: 210 & 191.

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: June 25, 2002 (67 FR 42820). The supplements dated August 7, and October 9 and October 30, 2002, and January 15, 2003, provided clarifying information that did not change the scope of the April 18, 2002, application nor the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 4, 2003.

No significant hazards consideration comments received: No.

Energy Northwest, Docket No. 50-397, Columbia Generating Station, Benton County, Washington

Date of application for amendment: October 22, 2002.

Brief description of amendment: The amendment deletes TS 5.5.3, "Post Accident Sampling System (PASS)," and thereby eliminates the requirements to have and maintain the PASS at Columbia Generating Station. The amendment also addresses related changes to TS 5.5.2, "Primary Coolant Sources Outside Containment," and

License Condition 2.C.(13), "Post Accident Sampling."

Date of issuance: January 27, 2003.

Effective date: January 27, 2003, to be implemented within 60 days from the date of issuance.

Amendment No.: 184.

Facility Operating License No. NPF-21: The amendment revised the Facility Operating License and Technical Specifications.

Date of initial notice in Federal Register: December 24, 2002 (67 FR 78518). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 27, 2003.

No significant hazards consideration comments received: No.

Entergy Gulf States, Inc., and Entergy Operations, Inc., Docket No. 50-458, River Bend Station, Unit 1, West Feliciana Parish, Louisiana

Date of amendment request: May 14, 2002, as supplemented by letters dated July 9, August 2, September 16, and November 7 and 22, 2002.

Brief description of amendment: This amendment increases the licensed power level by approximately 1.7 percent from 3,039 megawatts thermal (MWt) to 3,091 MWt. These changes result from increased feedwater flow measurement accuracy to be achieved by utilizing high accuracy ultrasonic flow measurement instrumentation.

Date of issuance: January 31, 2003.

Effective date: As of the date of issuance and shall be implemented 60 days from the date of issuance.

Amendment No.: 129.

Facility Operating License No. NPF-47: The amendment revised the Facility Operating License and Technical Specifications.

Date of initial notice in Federal Register: June 11, 2002 (67 FR 40022). The July 9, August 2, September 16, and November 7 and 22, 2002, supplemental letters provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 31, 2003.

No significant hazards consideration comments received: No.

Entergy Nuclear Operations, Inc., Docket No. 50-286, Indian Point Nuclear Generating Unit No. 3, Westchester County, New York

Date of application for amendment: April 24, 2001, as supplemented on May 22, 2002.

Brief description of amendment: The amendment revised information in the