

requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for A Hearing in connection with these actions was published in the **Federal Register** as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.12(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC web site, <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

*Carolina Power & Light Company, Docket No. 50-324, Brunswick Steam Electric Plant, Unit 2, Brunswick County, North Carolina*

*Date of amendment request:* September 16, 2002.

*Brief description of amendment:* The amendment revises a license condition by deleting the requirement to include check valve MVD-V5008 in the facility check valve program.

*Date of issuance:* December 13, 2002.

*Effective date:* December 13, 2002.

*Amendment No.:* 251.

*Facility Operating License No. DPR-62:* Amendment revises Appendix B, "Additional Conditions."

*Date of initial notice in Federal Register:* November 12, 2002 (67 FR 68731).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 13, 2002.

*No significant hazards consideration comments received:* No.

*Calvert Cliffs Nuclear Power Plant, Inc., Docket Nos. 50-317 and 50-318, Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, Calvert County, Maryland*

*Date of application for amendments:* January 31, 2002, as supplemented on September 18, 2002.

*Brief description of amendments:* The amendments change the method of verifying boron concentration of each safety injection tank. Rather than taking a sample of each tank every 31 days, the revised technical specification surveillance requirement requires leakage into the tanks to be monitored every 12 hours and a sample to be taken every 6 months.

*Date of issuance:* December 19, 2002.

*Effective date:* As of the date of issuance to be implemented within 30 days.

*Amendment Nos.:* 255 and 232.

*Renewed Facility Operating License Nos. DPR-53 and DPR-69:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* April 16, 2002. The September 18, 2002, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of these amendments is contained in a Safety Evaluation dated December 19, 2002.

*No significant hazards consideration comments received:* No.

*Connecticut Yankee Atomic Power Company, Docket No. 50-213, Haddam Neck Plant, Middlesex County, Connecticut*

*Date of amendment request:* September 10, 2001, as supplemented by letters dated June 19 and November 8, 2002. The supplemental information provided clarification that did not change the scope or the initial no significant hazards consideration determination.

*Brief description of amendment:* The amendment revises TS 3/4.9.7 and the corresponding Bases to address the use of a single-failure-proof-handling system for the Spent Fuel Building and to remove the restriction on travel of crane loads in excess of 1800 pounds.

*Date of issuance:* December 17, 2002.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment No.:* 198.

*Facility Operating License No. DPR-61:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 5, 2002 (67 FR 10009).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 17, 2002.

*No significant hazards consideration comments received:* No.

*Duke Energy Corporation, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina*

*Date of application for amendments:* August 29, 2002.

*Brief description of amendments:* The amendments revised the Technical Specifications 3.8.4.7, to modify the note to eliminate the "once per 60 months" restriction on replacing the battery service test by the battery modified performance discharge test. Associated changes to the TS Bases are also included.

*Date of issuance:* December 17, 2002.

*Effective date:* As of the date of issuance and shall be implemented within 30 days from the date of issuance.

*Amendment Nos.:* 209 & 190.

*Facility Operating License Nos. NPF-9 and NPF-17:* Amendments revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 12, 2002 (67 FR 68733).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 17, 2002.

*No significant hazards consideration comments received:* No.

*Entergy Nuclear Operations, Docket No. 50-247, Indian Point Nuclear Generating Unit No. 2, Westchester County, New York*

*Date of application for amendment:* May 30, 2002, as supplemented on October 31, 2002.

*Brief description of amendment:* The amendment revised the requirements in several administrative programs in Technical Specification Section 6.0, "Administrative Controls." Specifically, the amendment: (1) Replaced the specific management titles for several organizational positions with generic titles, (2) replaced the title of the Quality Assurance Program Description