

with a reference to the quality assurance program described or referenced in the Updated Final Safety Analysis Report, and (3) deleted the functions of the Station Nuclear Safety and the Nuclear Facilities Safety Committees and the Vice President-Nuclear Power since their duties and responsibilities are described in the Quality Assurance Program Description.

Date of issuance: December 17, 2002.

Effective date: As of the date of issuance to be implemented within 60 days.

Amendment No.: 235.

Facility Operating License No. DPR-26: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: June 25, 2002 (67 FR 42824).

The October 31 supplemental letter provided clarifying information that did not expand the scope of the amendment or change the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 17, 2002.

No significant hazards consideration comments received: No.

Indiana Michigan Power Company, Docket No. 50-315, Donald C. Cook Nuclear Plant, Unit 1, Berrien County, Michigan

Date of application for amendment: June 28, 2002, as supplemented on October 15 (two separate letters), October 17, November 15, and December 6, 2002.

Brief description of amendment: The amendment increases the licensed reactor core power level by 1.66 percent from 3250 megawatts thermal (MWt) to 3304 MWt. The power level increase is considered a measurement uncertainty recapture power uprate.

Date of issuance: December 20, 2002.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment No.: 273.

Facility Operating License No. DPR-58: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: July 23, 2002 (67 FR 48219).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 20, 2002.

No significant hazards consideration comments received: No.

Omaha Public Power District, Docket No. 50-285, Fort Calhoun Station, Unit No. 1, Washington County, Nebraska

Date of amendment request: October 8, 2002.

Brief description of amendment: The amendment revised Technical Specification 2.7, "Electrical Systems," to increase the amount of diesel fuel oil required for seven days of emergency diesel generator operation.

Date of issuance: December 16, 2002.

Effective date: December 16, 2002, and to be implemented within 30 days of issuance.

Amendment No.: 213.

Facility Operating License No. DPR-40: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 12, 2002 (67 FR 68741).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated December 16, 2002.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant, Units 1 and 2, Appling County, Georgia

Date of application for amendments: June 24, 2002, as supplemented by letter dated September 24, 2002.

Brief description of amendments: The amendments delete Technical Specification 5.5.3, "Post Accident Sampling System (PASS)," and thereby eliminate the requirements to have and maintain the PASS at Plant Hatch.

Date of issuance: December 18, 2002.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: 235 & 177.

Renewed Facility Operating License Nos. DPR-57 and NPF-5: Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: August 6, 2002 (67 FR 50958).

The supplement dated September 24, 2002, provided clarifying information that did not change the scope of the June 24, 2002, application nor the initial proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 18, 2002.

No significant hazards consideration comments received: No.

STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas

Date of amendments request: October 24, 2001, as supplemented by correspondent e-mails dated August 27, 2002, and September 24, 2002.

Brief description of amendments: The amendments consist of relocating various Technical Specifications (TSs) to the Technical Specification Requirements Manual (TRM). The amendments will relocate TSs 3/4.1.3.3, 3/4.3.3.2, 3/4.3.3.11, 3/4.4.7, 3/4.4.9.2, 3/4.3.4.11, 3/4.7.2, 3/4.7.10, 3/4.9.3, 3/4.9.5, 3/4.9.7, 3/4.10.5, and 3/4.11.2.5 to the TRM. Their associated bases will also be relocated to the TRM to be consistent with relocation of the various TSs. In addition, the proposed amendment corrects various typographical and page numbering errors, deletes an outdated one-time exception, and makes minor formal changes to improve consistency.

Date of issuance: The license amendment is effective as of its date of issuance and shall be implemented within 6 months from the date of issuance.

Effective date: December 17, 2002.

Amendment Nos.: Unit 1—145; Unit 2—33.

Facility Operating License Nos. NPF-76 and NPF-80: The amendments revised the Technical Specifications.

Date of initial notice in Federal Register: February 5, 2002 (67 FR 5334).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated December 17, 2002.

No significant hazards consideration comments received: No.

Tennessee Valley Authority, Docket Nos. 50-259, 50-260, and 50-296, Browns Ferry Nuclear Plant, Units 1, 2, and 3, Limestone County, Alabama

Date of application for amendments: September 3, 2002.

Description of amendment request: The proposed amendment revised Surveillance Requirement (SR) 3.0.3 to extend the delay period, before entering a Limiting Condition for Operation, following a missed surveillance. The delay period is extended from the current limit of "* * * up to 24 hours or up to the limit of the specified Frequency, whichever is less" to "* * * up to 24 hours or up to the limit of the specified Frequency, whichever is greater." In addition, the following requirement is added to SR 3.0.3: "A risk evaluation shall be performed for